



## Fire Extinguishers

- All Space Only stands to have Fire Extinguishers - 1 x DcP Dry chemical Powder and 1 x CO2) - placed on the stand.
- Fire Extinguishers should be hung on a wall via a purpose-made wall mount or bracket or located on a fire extinguisher stand - not directly on the floor.
- Fire Extinguishers provided by exhibitors or their contractors can be removed at the end of the exhibition period.
- Double Decker stands: 1 Set of fire extinguishers to be placed on each floor or level of the structure - again hung from the wall or on a stand - not directly on the floor.
- Stands with A/C Units: 1 Set of fire extinguishers to be placed in the immediate vicinity of the A/C unit. This requirement is in addition to the fire extinguishers that are to be placed in the general area of the stand.

## Example Image:



## Air Conditioning Units

- Stands with A/C units must have louvre ventilation grilles built into walling or doors when in an enclosed space, comprised of aluminium.
- 1 x set of fire extinguishers is required in the immediate location
- These grilles are to ensure suitable exchange of air and to ensure proper ventilation of the units
- Closed rooms without ventilation grilles will not be acceptable, even if they are open at the top



- An exhaust fan and exhaust/ventilation pipe should be available, connected to the A/C unit, which directs upwards to disperse vented air

**Example image:**

